

**Christchurch  
City Council**



**CH2M Beca**

# **A Tale of Two Sludges – Trialling Operational Temperature Control of an Anaerobic Digester**

**Lee Liaw (Christchurch City Council) and Jamie Rovers (CH2M Beca)**

# CWTP- Overview

## Second Largest WWTP in NZ

- Average daily flow of 165,000m<sup>3</sup>
- Consent only requires carbonaceous treatment
- Final discharge via 3km off-shore ocean outfall
- Biosolids dried and applied to land




# CWTP - Digestion

Total Digester Volume:  
34,000m<sup>3</sup>



- Two thermophilic digesters (7,000m<sup>3</sup> each)
- Four mesophilic digesters (5,000m<sup>3</sup> each)

Receive:


- Primary sludge
- Secondary sludge



# Anaerobic Digestion




# Current Operation



# Problem Statement


## Spiral Hxers are old

- Hxers well outside of operational life span
- Maintenance issues
- Fouling and scaling
- Consent limitations
- Limited redundancy




# Options Assessment

- A. Replace spiral heat exchangers.  
Install chiller units.
- B. Retrofit chiller units to spiral heat exchangers.
- C. Divert secondary sludge directly to mesophilic digesters.
- D. Water to air heat exchanger (radiator) for heat dump.




# Trial Operation



# Risk Management

<b>Risks</b>	<b>Controls (Safety in Design)</b>
Foaming	Extensive consultation with client
Metabolic imbalance	Procedure developed with operations
Loss of temperature control	Ramp-up period
No automatic control	Extensive laboratory sampling regime
Reduced methane generation	Monitoring
Reduced digested biosolids dewaterability	Agreed stop criteria


# Operator Procedure



10. Enter thermophilic sludge temperature into spreadsheet

11. Enter WAS temperature reading into spreadsheet

12. Enter WAS totaliser reading into spreadsheet. Record this value in check list




			7/12/2016		
Task	Action	Parameter	Fill 1	Fill 2	Fill 3
Pre-fill Valve Changes	Close	1. 410.0 OV003			
		2. 410.1 OV030			
		3. 410.2 OV027			
	Open	4. 410.0 OV007			
		5. "Cooling Trial" Button			
		6. 415.0 OV222 (Fake Valve)			
		7. 407.0 OV002			
Pre-fill SCADA Changes	Enter into Spreadsheet	8. RSP 6			
		9. Digester 4 Total Sludge Feed			
		10. Thermophilic Sludge Temperature			
		11. WAS Temperature			
		12. Initial WAS Totaliser Reading (Record)	135.8		
		13. Scaling Factor	20%		20%
		14. Effective Sludge Mixture Temperature			
		15. New Thermophilic Sludge Spill Volume			

Inputs			
ID	Parameter	Value	Unit
9.	Digester 4 Total Sludge Feed	60	m³
10.	Thermophilic Sludge Temperature	45.6	°C
11.	WAS Temperature	17	°C
12.	Initial WAS Totaliser Reading	135.8	m³
13.	Scaling Factor	20%	-
14.	Desired Effective Sludge "Mixture" Temperature	35	°C
Outputs			
15.	Thermophilic Sludge Spill Volume	55.6	m³
18.	Final WAS Totaliser Reading	-	m³


13. Enter scaling factor from checklist into spreadsheet

To access spreadsheet, open "Sludge Cooling Trial Spreadsheet.xlsxm" located on the bottom left corner of the graphing screen.

# Trial Time-line



# Trial Outcomes – Volatile Solids Destruction




# Trial Outcomes – Biogas and Electricity


**Trial starts  
(8/12/16)**

**Ramp-up  
ends  
(16/01/17)**

**Trial ends  
(24/03/17)**



# Trial Outcomes – H<sub>2</sub>S



# Trial Outcomes – Digester Health and Operation

Parameter	Criteria for Success	Actual Performance	
Temperature	33 – 35°C	33 – 35°C	
Volatile solids destruction	No reduction	20% increase for the Test Digester but overall remained similar	
Volatile acids	<1,200 – 1,500 mg/L	<96 mg/L for Digester 4	
pH	6 – 8	7.3 – 7.5	
Biogas – methane content	No detrimental change from current	No significant change observed	
Biogas – Hydrogen sulfide content	No detrimental change from current	Significant improvement (down to 0 – 100ppm)	
Final dry cake solids	No detrimental change from current	Reduction of 4 – 6% DS	

# Trial Outcomes - Economics

	Proposed Solution	Estimated Capex	Estimated Opex
A	Replace spiral exchangers with closed cooling loop	High	High
B	Retrofit spiral exchangers with closed cooling loop	Medium	High
C	Divert secondary sludge directly to the mesophilic digesters for cooling	Low	Low to medium

# Questions?



**Christchurch  
City Council**



**CH2M Beca**