

An aerial photograph of the Auckland Central Business District (CBD) and surrounding areas. The image shows a dense cluster of skyscrapers and commercial buildings in the foreground, with a large body of water (the harbor) and a distant island (Rangitoto Island) visible in the background. The sky is blue with some light clouds. A semi-transparent blue and purple gradient box is overlaid on the left side of the image, containing the title and author information.

Rapid Flood Hazard Assessment for the Auckland CBD - An Overview

Shaun Jones

May 14, 2010

AECOM

Introduction

- Client: Metrowater & Auckland City Council
- As part of Auckland City Council's (ACC) “CBD into the Future” strategy shared spaces are proposed
- Time constraints on this process called for a Rapid Flood Hazard (RFH) assessment was undertaken by AECOM
- RFH model consisted of only ‘Rain on Grid’
- Drainage capacity was accounted for by adjusting hydrology


Presentation Overview

- Shared Space Overview
- Model Setup
 - Bathymetry
 - Hydrology
 - Adjusted Hyetographs
 - Simulation Setup
 - Sensitivity
- Results
- Model Limitations
- Conclusions
- Future Work

Shared Spaces

- ACC's "CBD into the Future" aims to transform the CBD into a business and cultural centre
- Shared Spaces is a concept where pedestrians and vehicles share the same space
 - Improves environment without banning traffic
 - Paved surfaces across the full width of the street
 - Central channel – no kerb and channel
- Proposed changes may affect overland flow paths

Shared Spaces – Location Plan



Shared Spaces

Darby Street Existing



Shared Space Design



Methodology Selection

1D/2D Coupled Model vs 2D Rapid model

- Definition:
 - 1D – links and nodes conveying flow in one direction
 - 2D – 3 dimensional surface terrain where water can travel in multiple directions
 - Rapid Flood Modelling – Utilising 2D modelling only to determine flood hazards
- Reasons for utilising 2D Rapid Model
 - Main flood area is low lying
 - Time constraints
 - Pipe network is very complex and would likely cause delays to the programme

Model Setup

Bathymetry

- Existing bathymetry setup used
 - LIDAR data
 - Design levels through Queen Street
 - Survey data through shared space areas
- Future bathymetry was upgraded in shared spaces using design levels
- Cells located within building footprints are set to 'land' to ensure correct overland flow around buildings

Model Setup

Hydrology


- TP108 design storms were used for 20, 50 and 100 year simulations
- Rain on grid method utilised to ensure correct allocation of overland flow
 - Assumption is rainfall = runoff (i.e. No infiltration losses)
 - Considered appropriate due to the majority of the area being impervious
- Assumptions for inletting were applied to the entire catchment
 - **Catchpits** drain 20l/s each except Queen Street and Shared Spaces where design capacity is 20yr storm
 - **Building Roofs** assumed to drain a 10yr storm (current regulation is for 20yr storm therefore assumption is conservative)
 - **Other Private Drainage** assume zero other private drainage and that all other private drainage contributes to road drainage

Model Setup

Adjusted Hyetographs

- To account for the assumed drainage capacity the hyetograph for rain on grid was adjusted

Step 1:
group areas with
similar characteristics
(i.e. Catchpit
distribution, roof
coverage etc)




Model Setup

Adjusted Hyetographs

Below is an example of 10yr peak intensity (building capacity)

Step 2:
Each drainage
component
has a peak
intensity




Model Setup

Adjusted Hyetographs

Each area has a percentage of roof/paved and roads


Step 3:
Each drainage
area has a
percentage
of each drainage
component



Model Setup

Adjusted Hyetographs

Using a %age area weighted method the hyetographs were summed. The result is a hyetograph for each area




Model Setup

Adjusted Hyetographs

- Volume is removed from calculations when buildings are set to land
- Hyetograph scaled up proportionately based on the % of each area that was set to land



Step 4: Scale Hyetograph



Model Setup

Adjusted Hyetographs

Step 5:
Adjust for
Spatially and
Temporally
Distributed
Rainfall



Spatially and
Temporally
Distributed
Rainfall as
DFS2 

Model Setup

Simulation Setup

The “rain on grid” method is very computationally demanding therefore:

- Due to the ‘peaky’ nature of the adjusted hyetographs and;
- Flooding begins to recede less than 2 hours after the peak

Simulation could be run from 11.30am to 3pm

Model Setup

Sensitivity

A sensitivity check was carried out to determine how critical our assumptions regarding drainage capacity are :

A purple-to-blue gradient circle containing the text "Step 6: Sensitivity Check".


Step 6:
Sensitivity
Check

	Roof downpipe capacity	Catchpit capacity
Sensitivity Check 1	5 year ARI	10l/s
Sensitivity Check 2	No private roof drainage (assume all downpipes blocked)	10l/s


Results show that fully blocked private drainage significantly effects flooding extent due to the additional volume

Results

Below shows typical results obtained from the model



Pre shared space



Post shared space

Flooding has been changed, however, generally flooding has been reduced

Limitations


The following limitations are applied to the Rapid Flood Hazard Model:

- Assumes the network has capacity to receive and convey the assumed drainage capacities for catchpits and private properties
- Ignores the effect of backwater due to tidal influences
- Results were to be used to gauge **relative** differences in flood extent and depth

Further Work

A detailed 1D/2D coupled model is currently being developed for:

- Shared Spaces development team
- FHM programme for Auckland City Council

An aerial photograph of a coastal region. The land is divided into a grid of rectangular parcels, likely agricultural or industrial. A body of water is visible at the bottom of the frame. The text "Thank You" and "Any Questions?" is overlaid on the left side of the image.

Thank You

Any Questions?