

Robust decision making in an uncertain future: a Wellington water supply case study

Geoff Williams
Senior Advisor Strategy



Water supply strategy workstreams




Water supply augmentation project


- Supported by Connect Water (Beca and WSP) and Dr Judy Lawrence
- Review supply upgrade options

Strategic planning tool 5-yearly update


- A WATHNET model
- Ongoing partnership with NIWA
- Aim to increase visibility over uncertainty

DAPP process



1. Decision context
 2. Assess vulnerabilities and opportunities
 3. Identify and evaluate options
 4. Design and evaluate pathways
 5. Design adaptive plan
 6. Implement the plan
 7. Monitor the plan
- 

Context



GWRC Long Term Plan


“Sufficient water is available to meet normal demand except in a drought with a severity of greater than or equal to 1 in 50 years”

Whaitua te Whanganui-a-Tara

“Increase the minimum flows over time to 80 per cent of MALF...”

Uncertainties – Demand for water

How well do we really understand demand for water?



The more stars the more water efficient

WATER RATING

A joint government and industry program
Licence No. 0001


4.5	litres per full flush
3	litres per half flush

3.0 litres per average flush
with Integral Basin


When tested in accordance with Standard AS/NZS 6400
For more information and to compare products, refer to:
www.waterrating.gov.au

Uncertainties – Environmental regulation

How far will changes go?



Uncertainties – Climate change and sea level rise



Summary of future scenarios

Environmental regulation

- MRF at 40%, 60%, 80% and 100%

Hydrology and demand

- 5000 replicate stochastic datasets (historic and RCP 4.5, 6.0, 8.5)

Sea level rise

- 0m, 1.5m

Residential per capita demand


- Existing, 10% reduction

Population growth

- Three projections (25th, 50th, 75th percentiles)

Level of service (community risk appetite)

- Shortfall probability 2%, 0.5% and 0.2%


A large red bracket on the right side of the slide, grouping the six scenario categories listed on the left. It starts at the top of the 'Environmental regulation' section and ends at the bottom of the 'Level of service' section.

192 scenario combinations for each of the three LoS

Supply/demand intervention options




Te Awa Kairangi/Hutt River



Bulk water treatment and distribution to demand centres

Wainuiomata and Orongorongo Rivers

Network performance



WATHNET network file with future options turned on/off in decision files

```
P1A1E1C1S1D1N10.txt
1 Wathnet decision file
2 22
3 4.000000E+05 1.000000E+00 0.000000E+00 0.000000E+00 0.000000E+00 1.010000E+00 0.000000E+00 1.000000E+00 0.000000E+00 1.300000E+00 0.000000E+00
4 Population EReg option Sea Lev rise Demand rstn No dist limt Res PCD mult Res PCD add Com PCD mult Com PCD add Leakage mult Leakage add
5
```

Scripts to:

- Create future scenario combinations e.g. P10A2E3C4S2D1N15
- Generate WATHNET network and decision files
- Read WATHNET result files

Excel to interpolate results to find LoS failure point

Pathway development

1. Preliminary analysis with reduced uncertainty to inform sensible action sequencing
2. Option stress test with full uncertainty
3. Refine options and pathways
4. Re-test

Pathway	Action							
	1	2	3	4	5	6	7	8
1	Low water loss investment	Meters + DM (20ML/d)	Pakuratahi 3GL	Managed Aquifer Recharge 10ML/d	Wainui 1.5GL	Pakuratahi 7GL	Porirua desal 25ML/d	Porirua desal 50ML/d
2	Medium water loss investment	Meters + DM (20ML/d)	Pakuratahi 3GL	Managed Aquifer Recharge 10ML/d	Wainui 1.5GL	Pakuratahi 7GL	Porirua desal 25ML/d	Porirua desal 50ML/d
3	High water loss investment (requires meters)	Meters + DM (20ML/d)	Pakuratahi 3GL	Managed Aquifer Recharge 10ML/d	Wainui 1.5GL	Pakuratahi 7GL	Porirua desal 25ML/d	Porirua desal 50ML/d

Option stress testing using NeSI HPC (supported by NIWA)



- Every Pathway/Action sequence stress tested against every future scenario
- Completed ~200B days of full system flow balance

Analysis and initial results

	Action								
Pathway	1	2	3	4	5	6	7	8	9
1	5%	9%	36%	57%	97%	99%	85%	100%	100%
2	17%	41%	84%	98%	100%	100%	100%	100%	100%
3	29%	36%	100%	100%	100%	100%	100%	100%	100%
4	5%	9%	17%	67%	77%	55%	98%	99%	
5	17%	41%	63%	98%	99%	90%	100%	100%	
6	5%	16%	33%	45%	97%				
7	17%	44%	82%	91%	100%				
8	29%	34%	100%	100%	100%				
9	5%	3%	10%	48%					
10	17%	35%	47%	92%					
11	5%	9%	36%	57%	97%	99%	99%	100%	
12	17%	41%	84%	98%	100%	100%	100%	100%	
13	29%	36%	100%	100%	100%	100%	100%	100%	

“Success score”

Can options be implemented before LoS failure occurs?

- All actions fail initially, BUT water loss management is a key success factor

Timing and leadtime

Pathway: P12, 100% MALF, all CC, PCD & SL scenarios (@LoS)

100% MALF



Timing and leadtime

Pathway: P12, 100% MALF, all CC, PCD & SL scenarios (@LoS)

100% MALF



Timing and leadtime

Pathway: P12, 100% MALF, all CC, PCD & SL scenarios (@LoS)

100% MALF



Timing and leadtime

Pathway: P12, 100% MALF, all CC, PCD & SL scenarios (@LoS)

100% MALF



Pathway performance

Current Situation

High water loss investment (requires meters)

Medium water loss investment

Low water loss investment

Managed Aquifer Recharge 10ML/d

Meters + DM (20ML/d)

Pakuratahi 3GL

Pakuratahi 7GL


Wainui 1.5GL

Porirua PRW 25ML/d


Porirua desal 25ML/d

Porirua desal 50ML/d

Population (000)



What does it mean?



- Growth, environmental regulation and community risk appetite dominate future uncertainty
- Current LoS failure will continue until supply/demand interventions are in place (realistically 10 years)
- Options are largely path independent so can be sequenced as needed to achieve objectives
- No signs of maladaptation under future scenarios
- What next? Adaptive plan, implement and monitor!